Compressed Liquid, Superheated Vapor and Two-Phase *Pvtx* Measurements for Carbon Dioxide (R744) + Difluoromethane (R32) + 1,1,1,2-Tetrafluoroethane (R134a) Mixture

Laura Fedele ^{C, S}

Construction Technologies Institute, CNR National Research Council, Padova, Italy laura.fedele@itc.cnr.it

Giovanni Di Nicola

Department of Industrial Engineering and Mathematical Sciences, Marche Polytechnic University, Ancona, Italy

> Davide Menegazzo Department of Industrial Engineering, University of Padua, Padova, Italy

Sebastiano Tomassetti Department of Industrial Engineering and Mathematical Sciences, Marche Polytechnic University, Ancona, Italy

> Patrizio Parrabbi and Filippo Capodoglio Angelantoni Test Technologies Srl, Massa Martana (PG), Italy

Sergio Bobbo Construction Technologies Institute, CNR National Research Council, Padova, Italy

Cascade refrigeration systems are frequently used in several refrigeration applications where single-stage or multistage systems are not suitable due to the very low evaporation temperatures required. CO_2 is a good solution for the low temperature cycle when the required evaporating temperature is higher than -55°C, that is higher than the triple point of carbon dioxide (216.58 K, 56.57 °C). For lower evaporating temperatures, mixtures formed by CO_2 and refrigerants with lower triple point offer an interesting solution as potential substitutes for the very high GWP refrigerant R23, commonly used at very low temperatures. However, the thermosphysical properties of these mixtures are still not well studied.

In this work, compressed liquid, superheated vapor and two-phase pvTx measurements for ternary systems containing carbon dioxide (R744), difluoromethane (R32), and 1,1,1,2-tetrafluoroethane (R134a) are presented. Compressed liquid density measurements were performed using a vibrating tube densimeter along various isotherms from (283.15 to 353.15) K with steps of 10 K and for pressures from close to saturation up to 35 MPa. Two-phase and superheated vapor pvTx properties were measured with an isochoric apparatus along various isochores at temperatures from (223.15 to 303.15) K. The estimated uncertainties for the measurements is lower than 1 kg·m⁻³ for the liquid density and 0.005 m³· kg⁻¹ for the vapor specific volume.